

Location: _____



FRP

2 1/2" THRU 10" REDUCED PRESSURE ZONE BACKFLOW ASSEMBLIES



Specification: The BEECO Friendly Reduced Pressure Zone Backflow Preventer Valve is designed to stop the reverse of flow of a liquid into a potable water system. The proper installation of a backflow preventer must be done by a certified expert under local codes and guidelines to assure the protection of the drinking water system. The Valve shall be certified to ASSE 1013. Is Certified to cUPC and IAPMO listed.

Function: The assembly shall consist of two repairable positive seating check modules with captured springs and rubber seat discs. Service of all internal components shall be through a single easily removable cover and designed for ease of access. The valve shall have a relief valve to atmosphere.

Features: Single access cover for fast service, Swing away clamp for ease of removing checks, Modular design reducing number of spare parts, Self contained check so there is no pressure to relieve when changing the seats. The relief valve like the checks are easily repairable in line and is positioned for maximum protection in the vertical up position.

Ratings: Maximum working water pressure 175 PSI, Maximum working temperature 140° F, Hydrostatic test pressure 350 PSI, Flanged end connection meet ANSI B16.1 and all grooved dimensions comply with AWWA C606.

Complies with AWWA-C511



Model No.	Size	L	H OSY Open	H NRS	D
FRP2.50	2 1/2"	33.5	18.88	16.38	9.75
FRP3.00	3"	34.5	21.88	18.88	9.75
FRP4.00	4"	40.8	25.63	21.63	9.75
FRP6.00	6"	43.8	35.13	29.13	11.25
FRP8.00	8"	56.5	44.63	36.63	15.75
FRP10.00	10"	59.5	54.5	44.5	15.75

SUFFIX	OPTIONAL VARIATIONS
-NRS	Non Rising Stem Gate Valve
-OSY	Outside Stem and Yoke Gate Valve
-BA	Meets Buy America and Pennsylvania Steel Act
-S	Strainer Attached
-DCDA	Double Check Detector Assembly
-G	Grooved Flange Connection
-LF	No Gate Valves

CALIFORNIA PROPOSITION 65 WARNING. This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm.

Job Name: _____ Page No: _____
 Section No: _____ Contractor: _____
 Schedule No: _____ Purchase Order No: _____